LISTING SERVICE

LISTING No.   7300-0028:188   Page 1 of 1

CATEGORY: Misc. Devices/Control Unit Accessories

LISTEE: Notifier, One Fire-Lite Place, Northford, CT 06472-1653
Contact: Lawrence Flood (203) 484-1200 Fax (203) 484-7309

DESIGN: Model TPI-232 modem and TPI-AC/DC plug-in transformer. Model TPI-232 provides an interface between fire alarm control panel to an EIA-232 serial peripheral (CRT or printer) via a dedicated leased telephone line. Model TPI-AC/DC is a plug-in Class 2 transformer and is intended to be installed within a listed enclosure. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: TPI-232:   12 or 24 VDC
TPI-AC/DC: 120 VAC primary, 12 VDC secondary

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, product designation, electrical rating and UL label.

APPROVAL: Listed as control unit accessories for use with separately listed electrically and functionally compatible fire alarm control units.

06-01-97

This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 6, 2003**   *Listing Expires **June 30, 2004***

Authorized By: **DIANE K. AREND**, *Senior Deputy*
Program Manager